



Jianmin Zhang
Director of Engineering
19001 Kermier Rd.
Waller TX 77484

June 1, 2021

To: Whom it may concern

Regarding: Approval of IPEX 1738 venting system

The IPEX 1738 PVC venting system, installed in accordance with all manufacturer guidelines as outlined in the installation manual including the use of a primer that meets ASTM F656 and solvent that meets ASTM D2564 is approved for use with Goodman, Amana, and Daikin brand condensing furnaces.